



TEST CERTIFICATE

SUMMARY OF TEST RESULTS

NUMBER	0413	DATE	08 /03 / 04
Client' s data:	ALUMIL – MILONAS S.A. Industrial Area Kilkis GR 611 00 KILKIS GREECE		
Product description:	DOUBLE SASH DOOR OPENING / TILTING		
Material:	ALUMINIUM		
System :	M 9650 Alutherm Light		



2195 x 1450 mm

Air Permeability ELOT EN 1026:2000 / ELOT EN 12207:2000	Class 4
Watertightness ELOT EN 1027:2000 / ELOT EN 12208:2000	Class 9A
Resistance to Wind Load ELOT EN 12211:2000 / ELOT EN 12210:2000	Class C4

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.

MARIANTHI CHATZIANTONIOU
TECHNICAL MANAGER

IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL